

Tender Questions & Answers

FROM:	DANISH REFUGEE COUNCIL
Tender No:	RFQ_00248425 & 00248338
Tender Title:	Fire Safety Equipment/ Yangın Güvenliği Ek
Tender Issuing Date:	06-07-2023
Tender Closing Date:	13-07-2023

Danish Refugee Council Turkey has in reference to above tender period received the following questions to the Tender, and hereby provides responsive answers by best endeavour to all relevant Vendors & Suppliers.

#	Enquiries to the Tender		
	Date	Question	Answer
1	08-07-2023	MAP powder ratio and the standards to be applied	MAP ratio should be minimum 40% as per TSE standards
2	08-07-2023	MED certification is not available for 1 Kg fire extinguishers	MED certification is not required for both 1 Kg & 6 Kg fire extinguishers anymore. Please abide by TSE standards available in Turkey for fire extinguishers.
3	10-07-2023	Please provide visuals for "SHOVEL"	Please see below for "Sample Image 1"
4	10-07-2023	Please provide visuals for "HOE"	Please see below for "Sample Image 2"

On behalf of DRC

Yours sincerely,

Samet Bayrak

Supply Chain Manager

11 JUL 2023

Sample Image 1 - Shovel Head



Sample Image 2 - Hoe

